



NOTES:

1. REFER TO BOILER INSTALLATION DRAWINGS FOR RECOMMENDED FIELD INSTALLATION.
2. REFER TO SMARTPLATE APPLICATIONS GUIDE, SP-1010, FOR BUFFER TANK SIZING.
3. REFER TO SMARTPLATE INSTALLATION DRAWINGS FOR RECOMMENDED DOMESTIC PIPING INSTALLATION.

SD-A-772
 SD-A-773
 SD-A-774
 SD-A-775
 SD-A-776
 SD-A-777

4. BOILER PUMP MUST BE SIZED TO PROVIDE THE APPROPRIATE FLOW AT THE DESIGN ΔT OF THE BOILER PLANT. BOILER PUMP MUST MAINTAIN BENCHMARK BOILER(S) REQUIRED MINIMUM FLOW AS PER TECHNICAL DATA SHEET.

AERCO INTERNATIONAL, INC.
 Blauvelt, NY 10913

SMARTPLATE & BMK MULTIPLE UNITS
 WITH BOILER SIDE 2-PORT BUFFER TANK
 DEDICATED TO DOMESTIC WATER HEATING

DWN. BY K.S. DATE 011713
 SCALE NTS
 APPD. _____ DATE _____

SD-A-794

REV.
 E